

## **Standard 20-1997 (R2006) -- Method of Testing for Rating Remote Mechanical-Draft Air-Cooled Refrigerant Condensers (ANSI Approved)**

This reaffirmation of ANSI/ASHRAE Standard 20-1997 prescribes methods of laboratory testing to measure the heat rejection capabilities of remote mechanical draft, air-cooled refrigerant condensers for refrigerating and air conditioning. The objective is to ensure uniform performance information for establishing ratings.

The changes made for the 2006 reaffirmation were that the references were updated.

Units: Dual

**Product Code(s):** 86039